

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. Inv/2025-2026/012

Dated: 05/05/2026

It is certified that an inspection team headed by **Inder Mani, Operation Manager** from **Invinisia Technologies Private Limited** inspected the **Sunbeam Academy Samneghat, Varanasi, Address - Samne Ghat Road, Bhagwanpur, Varanasi, Uttar Pradesh-221005** on **05/05/2026** and on the basis of Water Test Report (Attached) dated **05/05/2026**

Sunbeam Academy, Samneghat, Varanasi has **safe drinking water facilities** for the **students and members of staff** of the institution. The School **maintains** the **hygienic sanitation** condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate shall remain valid till 05/05/2027



Signature with Seal:
Name : Inder Mani
Designation : Operation Manager
Name & Address of the Office / Department:
N.9/38-R-7-R new Colony Kakarmatta,
Varanasi, Uttar Pradesh, PIN-221004.

To,
Sunbeam Academy, Samneghat, Varanasi
Samne Ghat Road, Bhagwanpur, Varanasi, Uttar Pradesh-221005

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies



INVINSIA

WATER TEST REPORT

SAMPEL SOURCE: SUNBEAM ACADEMY, SAMNEGHTAT, VARANASI

TEST PROTOCOL: POTABLE WATER TEST

| | |
|---|----------------------------|
| 1. TURBIDITY | : < 5 NTU |
| 2. COLOUR | : Colourless |
| 3. TASTE & ODOUR | : Un Objectionable |
| 4. pH VALUE | : 7.4 |
| 5. TOTAL DISSOLVED SOLIDS | : 85 ppm. |
| 6. CHLORIDES | : 08 ppm. |
| 7. SULPHATES | : Nil |
| 8. FLUORIDE | : Nil |
| 9. NITRATES | : 1ppm |
| 10. NITRITES | : Nil |
| 11. CALCIUM | : 20ppm. |
| 12. MAGNESIUM | : 15ppm. |
| 13. TOTAL HARDNESS AS CaCO ₃ | : 40ppm. |
| 14. IRON | : 0.02ppm. |
| 15. RESIDUAL CHLORINE | : Nil (R.O. Treated water) |

Observations: All parameter suits to best potable water limits.

CONCLUSIVE RESULT: Sample was found to be fit for potable use

Signature with Seal



Dated : 05/05/2026

INVINSIA TECHNOLOGIES PVT. LTD.

Regd. Office: 13/2 Kabir Nagar, Durgakund, Varanasi-221005, U.P

Website: www.invinsia.com | E-Mail: info@invinsia.com | Contact No.: +917052896807, +918957111042